



Township Public Schools
50 Nellis Drive, Wayne, New Jersey 07470

Administrative Offices
www.wayneschools.com
Phone: (973) 633-3000
Fax: (973) 628-8058

Wayne Township Public Schools Annual Asbestos Notification Compliance – 2018 - 2019

To Parents, Guardians, Staff, Students and Members of the General Public:

The Wayne Township Public School District has completed its required inspections of the district facilities in accordance with the Asbestos Hazard Emergency Response Act (AHERA) 40 CFR Part 763.84 and 40 CFR 763.93. As part of this inspection process, we as a district are required to notify parents, faculty, and staff annually of any pertinent changes in the district relating to asbestos containing materials. The inspection reports are on file at each individual school and a complete district-wide set is available at the Department of Building Services, 50 Nellis Drive, Wayne, NJ.

To assure that all buildings are safe and in compliance with the requirements of AHERA, the district has retained the services of RAMM Environmental Services, Inc., Fair Lawn, New Jersey. This company is certified by the State Department of Health to inspect each building for ACM and develop a plan for the management of these materials. The AHERA Management Plan for each building documents the location and condition of asbestos and presents a plan of action for removal and/or maintenance of these materials.

All asbestos containing materials within the district are part of an ongoing Operations & Maintenance Program to keep the materials properly maintained. This year, asbestos containing floor tile were properly removed and disposed of by licensed asbestos contractors at our: Wayne Hills HS: room 140; Wayne Valley HS: rooms 103, 210, 211, 212, 214, Randall Carter ES: rooms 8, 12, 24 & nurse's office; Lafayette ES: rooms 20 & 21; Pines Lake ES: rooms 9 & 11; Schuyler Colfax MS: required a Sub-Chapter 8 removal and filing for permit included notification to the Department of Community Affairs. The damages were due to a winter freeze of a heating line causing extensive damage to rooms 131, 132 & 133 on Jan. 2nd.

The district also ensures that air testing and inspections are performed after removal to ensure the safety of our staff and children as well as keeping in full compliance with the law. Complete reports for removal projects have been placed in our AHERA files and are incorporated into our Asbestos Management Plans during the next re-inspection cycle.

In July 2018 the Asbestos AHERA Six-Month Surveillance Inspection Report was completed for all buildings containing ACM. Every six months all identified ACM are re-inspected by RAMM Environmental Services, Inc. for possible deterioration. If any deterioration is found, the area is repaired and cleaned by trained and certified personnel. The AHERA Six-Month Surveillance and Inspection Reports are on file.

Asbestos abatement and maintenance is conducted within the guidelines of Asbestos Containing Materials in Schools: Final Rule and Notice (40 CFR Part 763). Specific details about asbestos removal activities will be announced 10 days prior to the start of any such project filing for a permit through the the Dept. of Labor and Health. Tests will be taken of the air quality during and after each removal project.

Respectfully,
John Maso, Director of Facilities Management