



Administrative Offices  
www.wayneschools.com  
Phone: (973) 633-3000  
Fax: (973) 628-8058

## Wayne Township Public Schools Annual Asbestos Notification Compliance – 2021-2022

The Wayne Township Public School District has completed its required inspections of the district facilities in accordance with the Asbestos Hazard Emergency Response Act (AHERA) 40 CFR Part 763.84 and 40 CFR 763.93. As part of this inspection process, we are required to notify parents, faculty, and staff annually of any pertinent changes in the district relating to asbestos containing materials. The inspection reports are on file at each individual school and a complete district-wide set is available at the Department of Building Services, 50 Nellis Drive, Wayne, NJ.

To assure that all buildings are safe and in compliance with the requirements of AHERA, the district has retained the services of RAMM Environmental Services, Inc., Fair Lawn, New Jersey. This company is certified by the State Department of Health to inspect each building for ACM and develop a plan for the management of these materials. The AHERA Management Plan for each building documents the location and condition of asbestos and presents a plan of action for removal and/or maintenance of these materials.

### **All asbestos containing materials within the district are part of an ongoing Operations & Maintenance Program.**

The majority of pipe insulation, pipe joint insulation, and all boiler insulation, breeching insulation, flu patching, fire bricks, and fire door insulation was removed from Boiler Room 1 and Boiler Room 2 at **Wayne Valley High School** (Spring 2021).

All floor tiles were removed in Room 141 at **Wayne Hills High School** (Summer 2021).

All floor tiles were removed from storage by Gym, Cafeteria, and Classroom 17 at **Theunis Dey Elementary School** (Summer 2021).

All Floor Tiles were removed from Room 145 at **Schuyler-Colfax Middle School** (Summer 2021).

All floor tiles were removed from Room 14 at **Randall Carter Elementary School** (Summer 2021).

All floor tiles were removed from room 209 at **George Washington Middle School** (Summer 2021).

30 s.f. of 9" x 9" vinyl floor tiles were removed in Nurse's room at **Albert P. Terhune Elementary School** (Summer 2021).

The district also ensures that air testing and inspections are performed after removal to ensure the safety of our staff and children as well as remaining in full compliance with the law. Complete reports for removal project have been placed in our AHERA files and will be incorporated into our Asbestos Management Plan during the next re-inspection cycle.

In **July 2022** the Asbestos AHERA Six-Month Surveillance Inspection Report was completed for all buildings containing ACM. Every six months all identified ACM are re-inspected by RAMM Environmental Services, Inc. for possible deterioration. If any deterioration is found, the area is repaired and cleaned by trained and certified personnel. The AHERA Six-Month Surveillance and Inspection Reports are on file.

Asbestos abatement and maintenance is conducted within the guidelines of [Asbestos Containing Materials in Schools; Final Rule and Notice \(40 CFR Part 763\)](#). Specific details about asbestos removal activities will be announced 10 days prior to the start of any such project filing for a permit through the Dept. of Labor and Health. Tests will be taken of the air quality immediately after each removal project.

Peter Romain, Director of Facilities, Operations