

PINES LAKE ELEMENTARY			
511 PINES LAKE DRIVE			
KEY :	TNR: TESTING NOT REQUIRED		
	DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION		
	ND: NONE DETECTED BS: BELOW DEP / EPA STANDARD		
	SP: NON POTABLE WATER (NOT FOR DRINKING) FOR HAND WASHING ONLY	TEST DATES: 10/7/16 & 10/11/16 & 10/13/16	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439858-1	CLASSROOM 27 SINK	1.100	TNR/BS
L6439858-2	CLASSROOM 6 SINK	ND	TNR/BS
L6439858-3	CLASSROOM 8 SINK	1.500	TNR/BS
L6439858-4	CLASSROOM 11 SINK	ND	TNR/BS
L6439858-5	CLASSROOM 10 SINK	ND	TNR/BS
L6439858-6	CLASSROOM 12 SINK	ND	TNR/BS
L6439858-7	CLASSROOM 13 SINK	2.700	TNR/BS
L6439858-8	CLASSROOM 7 SINK	ND	TNR/BS
L6439858-9	CLASSROOM 9 SINK	2.800	TNR/BS
L6439858-10	TRAILER FOUNTAIN	ND	BS
L6439858-11	WATER FOUNTAIN RIGHT BY MEDIA CENTER	ND	BS
L6439858-12	TRAILER SINK	ND	TNR/BS
L6439858-13	WATER FOUNTAIN LEFT BY MEDIA CENTER	ND	BS
L6439858-14	CLASSROOM 27 FOUNTAIN	ND	BS
L6439858-15	FOUNTAIN BY CLASSROOM 9	ND	BS
L6509864-1	CLASSROOM 2 SINK	1.300	TNR/BS
L6509864-2	FOUNTAIN BY CLASSROOM 21	1.800	BS
L6509864-3	TEACHERS ROOM SINK	9.200	BS
L6509864-4	FOUNTAIN RIGHT BY MAIN OFFICE	ND	BS
L6509864-5	KITCHEN SINK LEFT	ND	BS
L6509864-6	FOUNTAIN BY CLASSROOM 24	ND	BS
L6509864-7	CLASSROOM 20 FOUNTAIN	ND	BS
L6509864-8	CLASSROOM 24 FOUNTAIN	10.800	BS
L6509864-9	CLASSROOM 21 SINK	1.900	TNR/BS
L6509864-10	CLASSROOM 25 SINK	1.800	TNR/BS
L6509864-11	KITCHEN SINK RIGHT	ND	BS
L6509864-12	FOUNTAIN LEFT BY MAIN OFFICE	ND	BS
L6509864-13	KINDERGARTEN FOUNTAIN	ND	BS
L6509864-14	CLASSROOM 23 SINK	ND	TNR/BS
L6509864-15	CLASSROOM 23 FOUNTAIN	2.300	BS
L6509864-16	CLASSROOM 21 FOUNTAIN	ND	BS
L6509864-17	CLASSROOM 20 SINK	1.400	TNR/BS
L6509864-18	CLASSROOM 22 SINK	1.200	TNR/BS
L6509864-19	KITCHEN SIDE SINK	3.100	BS
L6509864-20	CLASSROOM 25 FOUNTAIN	ND	BS
L6509864-21	KINDERGARTEN SINK	1.700	BS

PINES LAKE ELEMENTARY			
511 PINES LAKE DRIVE			
KEY :	TNR: TESTING NOT REQUIRED		
	DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION		
	ND: NONE DETECTED BS: BELOW DEP / EPA STANDARD		
	SP: NON POTABLEWATER (NOT FOR DRINKING) FOR HAND WASHING ONLY	TEST DATES: 10/7/16 & 10/11/16 & 10/13/16	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6509864-22	KITCHEN SMALL SINK	ND	BS
L6509864-23	BOYS ROOM SINK 3	1.500	TNR/BS
L6509864-24	CLASSROOM 1 SINK	4.400	TNR/BS
L6509864-25	CLASSROOM 2 SINK	1.300	TNR/BS
L6509864-26	FOUNTAIN BY ART ROOM	ND	BS
L6509864-27	BOYS ROOM SINK 2	2.900	TNR/BS
L6509864-28	BOYS ROOM SINK 1	4.800	TNR/BS
L6509864-29	FOUNTAIN RIGHT BY ROOM 35	ND	BS
L6509864-30	FOUNTIAN LEFT BY ROOM 35	ND	BS
L6509864-31	MEDIA CENTER SINK	ND	BS
L6509864-32	CLASSROOM 3 SINK	2.200	TNR/BS
L6509864-33	MAIN OFFICE SINK	ND	BS
L6509864-34	FOUNTAIN BY TEACHERS ROOM	ND	BS
L6509864-35	TEACHERS ROOM SINK	ND	BS
L6509864-36	NURSES OFFICE SINK	1.600	BS
L6509864-37	TEACHERS ROOM BATHROOM SINK	ND	TNR/BS