

**GEORGE WASHINGTON MIDDLE SCHOOL****68 LENNOX ROAD****KEY: TNR: TESTING NOT REQUIRED**  
**DEP & EPA STANDARD LEAD LEVEL: 15.000 PARTS PER BILLION**  
**ND: None Detected BS: Below DEP/EPA Standard****SP: NON POTABLE (NOT FOR DRINKING) FOR HAND WASHING ONLY****Test Date - 10/22/16**

<b>SAMPLE NUMBER</b>	<b>DESCRIPTION</b>	<b>TEST RESULTS</b>	<b>REMEDIAL ACTION NOTES</b>
L6522839-1	NURSES OFFICE FRONT	ND	BS
L6522839-2	FOUNTAIN 3 BY ROOM 217	ND	BS
L6522839-3	CLASSROOM 106 SINK	1.600	TNR/ BS
L6522839-4	CLASSROOM 230 SINK	>15 ppb	TNR/ SP
L6522839-5	ART ROOM 209 SINK BY STORAGE	1.900	TNR/ BS
L6522839-6	SCIENCE LAB 229 SINK FRONT	<15 ppb	TNR/ BS
L6522839-7	ART ROOM #209 SINK LEFT	1.400	TNR/ BS
L6522839-8	FOUNTAIN 2 BY ROOM 217	ND	BS
L6522839-9	FOUNTAIN RIGHT BY ROOM 109	ND	BS
L6522839-10	FOUNTAIN BY CUSTODIAN RM 210	ND	BS
L6522839-11	FOUNTAIN LEFT BY MAIN ENT	ND	BS
L6522839-12	FOUNTAIN 1 BY ROOM 217	ND	BS
L6522839-13	SCIENCE LAB 225 SINK 3	<15 ppb	TNR/ BS
L6522839-14	MUSIC ROOM 110 SINK	>15 ppb	TNR/ BS
L6522839-15	FOUNTAIN OUTSIDE GIRLS LOCKER ROOM	1.800	BS
L6522839-16	KITCHEN SMALL SINK IN BREAK ROOM	2.100	BS
L6522839-17	SCIENCE LAB 225 SINK BY WINDOW	>15 ppb	TNR/ SP
L6522839-18	ART ROOM 207 MAIN SINK BY STORAGE	1.100	TNR/ BS
L6522839-19	ART ROOM 207 MAIN SINK RIGHT	1.600	TNR/ BS
L6522839-20	CLASS ROOM 127 SINK	>15 ppb	TNR/ SP
L6522839-21	KITCHEN SINK ON LARGE ISLAND	1.100	BS
L6522839-22	MUSIC ROOM 109 SINK	3.200	TNR/ BS
L6522839-23	NURSES OFFICE SINK	1.600	BS
L6522839-24	MAIN OFFICE SINK	3.000	BS
L6522839-25	SCIENCE LAB 227 SINK 3	>15 ppb	TNR/ SP
L6522839-26	TEACHERS ROOM SINK	ND	BS
L6522839-27	PREP ROOM 227-229 SINK	ND	TNR/ BS
L6522839-28	FOUNTAIN RIGHT BY MAIN ENT	ND	BS
L6522839-29	SCIENCE LAB 227 SINK BY WINDOW	>15 ppb	TNR/ SP
L6522839-30	GIRLS LOCKER ROOM OFFICE SINK	1.300	TNR/ BS
L6522839-31	SCIENCE LAB 225 SINK FRONT	>15 ppb	TNR/ SP
L6522839-32	FOUNTAIN 3 BY COURTYARD	ND	BS
L6522839-33	CAFETERIA WEST FOUNTAIN	5.000	BS
L6522839-34	CLASSROOM 224 SINK	5.100	TNR/ BS
L6522839-35	WOOD SHOP SINK RIGHT	8.800	TNR/ BS

L6522839-36	FOUNTAIN 2 BY COURTYARD	ND	BS
<b>GEORGE WASHINGTON MIDDLE SCHOOL</b>			
<b>68 LENNOX ROAD</b>			
<b>KEY:</b>	<b>TNR: TESTING NOT REQUIRED</b>		
	<b>DEP &amp; EPA STANDARD LEAD LEVEL: 15.000 PARTS PER BILLION</b>		
	<b>ND: None Detected      BS: Below DEP/EPA Standard</b>		
	<b>SP: NON POTABLE (NOT FOR DRINKING) FOR HAND WASHING ONLY</b>		<b>Test Date - 10/22/16</b>
<b>SAMPLE NUMBER</b>	<b>DESCRIPTION</b>	<b>TEST RESULTS</b>	<b>REMEDIAL ACTION NOTES</b>
L6522839-37	FOUNTAIN 1 BY COURTYARD	ND	BS
L6522839-38	KITCHEN SINK LEFT ON WALL	ND	BS
L6522839-39	FOUNTAIN BY CLASSROOM 125	ND	BS
L6522839-40	FOUNTAIN 2ND FL BY ELEVATOR	ND	BS
L6522839-41	FOUNTAIN BY MAIN OFFICE	1.100	BS
L6522839-42	FOUNTAIN LEFT BY ROOM 109	ND	BS
L6522839-43	WOOD SHOP SINK LEFT	<15 ppb	TNR/ BS
L6522839-44	FOUNTAIN 4 BY COURTYARD	ND	BS
L6522839-45	KITCHEN SINK ON SMALL ISLAND	1.300	BS
L6522839-46	BOYS LOCKER ROOM OFFICE SINK	2.200	TNR/ BS
L6522839-47	CAFETERIA FOUNTAIN	4.000	BS
L6522839-48	MEDIA CENTER SINK	ND	BS
L6522839-49	COFFEE MAKER IN KITCHEN	1.500	BS
L6522839-50	FOUNTAIN IN BOYS LOCKER ROOM	< 15 ppb	BS
L6522839-51	FOUNTAIN IN WOOD SHOP	5.300	BS
L6522839-52	FOUNTAIN IN GIRLS LOCKER ROOM	7.500	BS
L6522839-53	SHOP SINK IN WOOD SHOP	<15 ppb	TNR/ BS
L6522839-54	SCIENCE LAB 229 SINK BY WINDOW	5.000	TNR/ BS
L6522839-55	SCIENCE LAB 229 SINK 3	4.400	TNR/ BS
L6522839-56	SCIENCE LAB 227 SINK FRONT	>15 ppb	TNR/ SP
L6522839-57	CLASSROOM 208 SINK	>15 ppb	TNR/ SP
L6522839-58	KITCHEN SINK RIGHT ON WALL	ND	BS
L6522839-59	CUSTODIANS OFFICE SINK	ND	BS
L6522839-60	FOUNTAIN BY S GYM	ND	BS
L6522839-62	FOUNTAIN NEXT TO CAFETERIA	4.000	BS
L6522839-63	KITCHEN SINK IN BREAK ROOM	<15 ppb	BS
L6522839-64	SCIENCE ROOM 223 SINK FRONT	>15 ppb	TNR/ BS
L6522839-65	SCIENCE LAB 223 SINK BY WINDOW	<15 ppb	TNR/ BS
L6522839-66	SCIENCE LAB 223 SINK 3	<15 ppb	TNR/ BS
L6522839-67	SCIENCE LAB PREP RM SINK 223-225	<15 ppb	TNR/ BS