

WAYNE HILLS HIGH SCHOOL

272 BERDAN AVE

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/8/16 & 5/31/17

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-1	LAB 259 # 4 FRONT SINK	<15 ppb	TNR/BS
L6439886-2	LAB 286 ISLAND 3 SINK LEFT	<15 ppb	TNR/BS
L6439886-3	LAB 290 ISLAND 2 SINK RIGHT	<15 ppb	TNR/BS
L6439886-4	CLASSROOM 253 SINK 4	1.520	TNR/BS
L6439886-5	LAB 286 ISLAND 2 SINK LEFT	>15 ppb	TNR/ SP
L6439886-6	LAB 290 ISLAND 3 SINK RIGHT	<15 ppb	TNR/BS
L6439886-7	LAB 290 ISLAND 6 SINK RIGHT	>15 ppb	TNR/BS
L6439886-8	LAB 290 ISLAND 4 SINK LEFT	>15 ppb	TNR/ SP
L6439886-9	LAB 286 ISLAND 2 SINK RIGHT	>15 ppb	TNR/ SP
L6439886-10	LAB 292 ISLAND 6 SINK RIGHT	<15 ppb	TNR/BS
L6439886-11	FOUNTAIN BY ROOM 271	< 0.500	BS
L6439886-12	LAB 290 ISLAND 3 SINK LEFT	<15 ppb	TNR/BS
L6439886-13	LAB 290 ISLAND 2 SINK RIGHT	<15 ppb	TNR/BS
L6439886-14	LAB 286 ISLAND 1 SINK LEFT	>15 ppb	TNR/ SP
L6439886-15	LAB 292 FRONT SINK	>15 ppb	TNR/ SP
L6439886-16	LAB 290 ISLAND 6 SINK LEFT	<15 ppb	TNR/BS
L6439886-17	LAB 286 ISLAND 5 SINK LEFT	<15 ppb	TNR/BS
L6439886-18	CLASSROOM 253 SINK 5	1.260	TNR/BS
L6439886-19	LAB 259 SINK 3	<15 ppb	TNR/BS
L6439886-20	LAB 292 ISLAND 3 SINK LEFT	>15 ppb	TNR/ SP
L6439886-21	LAB 292 ISLAND 1 SINK LEFT	>15 ppb	TNR/BS
L6439886-22	LAB 286 ISLAND 1 SINK RIGHT	<15 ppb	TNR/BS
L6439886-23	FOUNTAIN BY MEDIA CENTER IN BACK	< 0.500	BS
L6439886-24	LAB 259 # 6 FRONT SINK	<15 ppb	TNR/BS
L6439886-25	LAB 259 SINK 2	<15 ppb	TNR/BS
L6439886-26	FOUNTAIN LEFT BY 289	< 0.500	BS
L6439886-27	FOUNTAIN RIGHT BY 289	< 0.500	BS
L6439886-28	FOUNTAIN BY GIRLS ROOM 263	< 0.500	BS
L6439886-29	LAB 259 # 3 FRONT SINK	<15 ppb	TNR/BS
L6439886-30	LAB 290 ISLAND 2 SINK LEFT	<15 ppb	TNR/BS
L6439886-31	LAB 290 ISLAND 5 SINK LEFT	<15 ppb	TNR/BS
L6439886-32	LAB 290 ISLAND 5 SINK RIGHT	<15 ppb	TNR/BS

WAYNE HILLS HIGH SCHOOL

272 BERDAN AVE

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/8/16 & 5/31/17

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-33	LAB 286 ISLAND 6 SINK LEFT	<15 ppb	TNR/BS
L6439886-34	LAB 259 # 6 BACK SINK	<15 ppb	TNR/BS
L6439886-35	LAB 259 # 5 FRONT SINK	<15 ppb	TNR/BS
L6439886-36	LAB 290 FRONT SINK	>15 ppb	TNR/ SP
L6439886-37	CLASSROOM 283 SINK 1	0.900	TNR/BS
L6439886-38	LAB 259 # 5 REAR SINK	>15 ppb	TNR/ SP
L6439886-39	CLASSROOM 283 SINK 3	1.220	TNR/BS
L6439886-40	LAB 259 FRONT SINK	<15 ppb	TNR/BS
L6439886-41	LAB 286 ISLAND 4 SINK RIGHT	<15 ppb	TNR/BS
L6439886-42	LAB 292 ISLAND 2 SINK LEFT	>15 ppb	TNR/ SP
L6439886-43	LAB 259 SINK 1	<15 ppb	TNR/BS
L6439886-44	LAB 259 # 5 BACK SINK	<15 ppb	TNR/BS
L6439886-45	LAB 292 SIDE SINK	>15 ppb	TNR/ SP
L6439886-46	LAB 292 ISLAND 4 SINK RIGHT	<15 ppb	TNR/BS
L6439886-47	LAB 259 # 1 BACK SINK	<15 ppb	TNR/BS
L6439886-48	LAB 292 ISLAND 3 SINK RIGHT	>15 ppb	TNR/ SP
L6439886-49	CLASSROOM 283 SINK 4	< 0.500	TNR/BS
L6439886-50	CLASSROOM 253 SINK 3	2.280	TNR/BS
L6439886-51	LAB 259 # 1 FRONT SINK	<15 ppb	TNR/BS
L6439886-52	CLASSROOM 283 SINK 2	0.820	TNR/BS
L6439886-53	LAB 259 # 4 BACK SINK	<15 ppb	TNR/BS
L6439886-54	CLASSROOM 283 SINK 5	0.950	TNR/BS
L6439886-55	LAB 292 ISLAND 6 SINK LEFT	<15 ppb	TNR/BS
L6439886-56	LAB 292 ISLAND 5 SINK RIGHT	<15 ppb	TNR/BS
L6439886-57	CLASSROOM 253 SINK 2	0.680	TNR/BS
L6439886-58	LAB 259 # 2 REAR SINK	<15 ppb	TNR/BS
L6439886-59	LAB 292 ISLAND 4 SINK LEFT	>15 ppb	TNR/ SP
L6439886-60	LAB 256 # 6 REAR SINK	>15 ppb	TNR/ SP
L6439886-61	FOUNTAIN BY 275	< 0.500	BS
L6439886-62	LAB 292 ISLAND 1 SINK RIGHT	<15 ppb	TNR/BS
L6439886-63	FOUNTAIN BY 282	0.520	BS
L6439886-64	LAB 259 # 1 REAR SINK	>15 ppb	TNR/ SP
L6439886-65	LAB 259 # 2 BACK SINK	<15 ppb	TNR/BS
L6439886-66	LAB 286 ISLAND 3 SINK RIGHT	<15 ppb	TNR/BS

WAYNE HILLS HIGH SCHOOL

272 BERDAN AVE

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/8/16 & 5/31/17

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-67	LAB 259 # 4 REAR SINK	>15 ppb	TNR/ SP
L6439886-68	PREP ROOM 286 SINK	3.290	TNR/BS
L6439886-69	LAB 259 # 2 FRONT SINK	<15 ppb	TNR/BS
L6439886-70	LAB 259 # 3 BACK SINK	<15 ppb	TNR/BS
L6439886-71	LAB 292 ISLAND 5 SINK LEFT	<15 ppb	TNR/BS
L6439886-72	LAB 259 # 3 REAR SINK	>15 ppb	TNR/ SP
L6439886-73	LAB 231 SINK 5	>15 ppb	TNR/ SP
L6439886-74	LAB 233 SINK 7	<15 ppb	TNR/BS
L6439886-75	LAB 235 SINK 5	<15 ppb	TNR/BS
L6439886-76	LAB 235 SINK 8	<15 ppb	TNR/BS
L6439886-77	LAB 233 SINK 1	>15 ppb	TNR/ SP
L6439886-78	FOUNTAIN LEFT BY 253	< 0.500	BS
L6439886-79	LAB 136 SINK 3	>15 ppb	TNR/ SP
L6439886-80	LAB 233 SINK 4	>15 ppb	TNR/ SP
L6439886-81	LAB 136 FRONT SINK	>15 ppb	TNR/ SP
L6439886-82	LAB 229 SINK 3	>15 ppb	TNR/ SP
L6439886-83	LAB 286 FRONT OFFICE SINK	>15 ppb	TNR/ SP
L6439886-84	LAB 231 FRONT SINK	>15 ppb	TNR/ SP
L6439886-85	LAB 137 SINK 2	<15 ppb	TNR/BS
L6439886-86	LAB 137 SINK 1	<15 ppb	TNR/BS
L6439886-87	LAB 233 SINK 2	<15 ppb	TNR/BS
L6439886-88	LAB 229 SINK 7	>15 ppb	TNR/ SP
L6439886-89	LAB 235 SINK 5	<15 ppb	TNR/BS
L6439886-90	LAB 229 SINK 1	>15 ppb	TNR/ SP
L6439886-91	PREP ROOM 231-233 SINK	1.250	TNR/BS
L6439886-92	PREP ROOM 229-228 SINK	1.030	TNR/BS
L6439886-93	LAB 137 FRONT SINK	>15 ppb	TNR/ SP
L6439886-94	LAB 233 SINK 5	>15 ppb	TNR/ SP
L6439886-95	LAB 228 SINK 4	>15 ppb	TNR/ SP
L6439886-96	LAB 228 SINK 5	>15 ppb	TNR/ SP
L6439886-97	CLASSROOM 256 SINK	6.350	TNR/BS
L6439886-98	LAB 137 SINK 4	>15 ppb	TNR/ SP
L6439886-99	LAB 229 SINK 6	>15 ppb	TNR/ SP
L6439886-100	LAB 136 SINK 6	>15 ppb	TNR/ SP

WAYNE HILLS HIGH SCHOOL

272 BERDAN AVE

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/8/16 & 5/31/17

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-101	LAB 235 FRONT SINK	>15 ppb	TNR/ SP
L6439886-102	LAB 235 SINK 7	<15 ppb	TNR/BS
L6439886-103	LAB 137 SINK 6	>15 ppb	TNR/ SP
L6439886-104	LAB 286 SINK LEFT	,15 ppb	TNR/BS
L6439886-105	LAB 231 SINK 1	<15 ppb	TNR/BS
L6439886-106	LAB 136 SINK 4	<15 ppb	TNR/BS
L6439886-107	LAB 137 SINK 3	<15 ppb	TNR/BS
L6439886-108	LAB 235 SINK 1	>15 ppb	TNR/ SP
L6439886-109	MEDIA CENTER SINK	0.870	BS
L6439886-110	LAB 233 FRONT SINK	>15 ppb	TNR/ SP
L6439886-111	LAB 136 SINK 2	<15 ppb	TNR/BS
L6439886-112	LAB 136 SINK 7	<15 ppb	TNR/BS
L6439886-113	LAB 235 SINK 3	<15 ppb	TNR/BS
L6439886-114	LAB 228 SINK 7	>15 ppb	TNR/ SP
L6439886-115	LAB 231 SINK 2	>15 ppb	TNR/ SP
L6439886-116	LAB 235 SINK 2	>15 ppb	TNR/ SP
L6439886-117	LAB 229 SINK 4	>15 ppb	TNR/ SP
L6439886-118	LAB 231 SINK 3	>15 ppb	TNR/ SP
L6439886-119	LAB 233 SINK 6	>15 ppb	TNR/ SP
L6439886-120	LAB 286 ISLAND 5 SINK RIGHT	<15 ppb	TNR/BS
L6439886-121	LAB 136 SINK 5	>15 ppb	TNR/ SP
L6439886-122	LAB 231 SINK 6	>15 ppb	TNR/ SP
L6439886-123	LAB 235 SINK 4	<15 ppb	TNR/BS
L6439886-124	LAB 228 FRONT SINK	>15 ppb	TNR/ SP
L6439886-125	LAB 229 SINK 5	>15 ppb	TNR/ SP
L6439886-126	CLASSROOM 253 SINK 6	2.120	TNR/BS
L6439886-127	LAB 137 SINK 7	>15 ppb	TNR/ SP
L6439886-128	LAB 286 ISLAND 6 SINK RIGHT	<15 ppb	TNR/BS
L6439886-129	CLASSROOM 253 SINK 1	1.550	TNR/BS
L6439886-130	LAB 228 SINK 6	>15 ppb	TNR/ SP
L6439886-131	FOUNTAIN RIGHT BY 253	< 0.500	BS
L6439886-132	FOUNTAIN BY FRONT OF MEDIA CENTER	3.330	BS
L6439886-133	LAB 231 SINK 4	>15 ppb	TNR/BS
L6439886-134	LAN 137 SINK 5	>15 ppb	TNR/ SP
L6439886-135	LAB 231 SINK 7	>15 ppb	TNR/ SP

WAYNE HILLS HIGH SCHOOL

272 BERDAN AVE

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/8/16 & 5/31/17

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-136	LAB 233 SINK 3	>15 ppb	TNR/ SP
L6439886-137	LAB 229 FRONT SINK	>15 ppb	TNR/ SP
L6439886-138	LAB 229 SINK 2	>15 ppb	TNR/ SP
L6439886-139	LAB 228 SINK 2	>15 ppb	TNR/ SP
L6439886-140	LAB 136 SINK 1	<15 ppb	TNR/BS
L6439886-141	LAB 286 FRONT SINK	>15 ppb	TNR/ SP
L6439886-142	FOUNTAIN IN CLASSROOM 119	0.720	BS
L6439886-143	GYM FOUNTAIN BY GIRLS ROOM LOCKER	0.800	BS
L6439886-144	FOUNTAIN LEFT BY 158	< 0.500	BS
L6439886-145	FOUNTAIN RIGHT BY 158	< 0.500	BS
L6439886-146	DRESSING ROOM BY 112 SINK LEFT	>15 ppb	TNR/ SP
L6439886-147	FOUNTAIN BY COMMONS	3.080	BS
L6439886-148	KITCHEN SINK IN BACK BY 143	< 0.500	BS
L6439886-149	FOUNTAIN SOUTH GYM 146	4.860	BS
L6439886-150	CLASSROOM 113 SINK 1	1.560	TNR/BS
L6439886-151	NURSES OFFICE SINK	0.800	BS
L6439886-152	KITCHEN 120 SINK LEFT	< 0.500	BS
L6439886-153	BOYS LOCKER ROOM 145 OFFICE SINK	< 0.500	TNR/BS
L6439886-154	CLASSROOM 140 SINK	0.630	TNR/BS
L6439886-155	GUIDANCE OFFICE SINK	< 0.500	BS
L6439886-156	KITCHEN 120 FAUCET BY STORE	< 0.500	BS
L6439886-157	KITCHEN FRONT SINK BY 143	<15 ppb	BS
L6439886-158	FOUNTAIN RIGHT BY BOYS LOCKER 145	< 0.500	BS
L6439886-159	COACHES LOCKER ROOM 150 SINK	1.050	BS
L6439886-160	KITCHEN 10 SINK ON ISLAND RIGHT	< 0.500	BS
L6439886-161	CLASSROOM 141 SINK	0.940	TNR/BS
L6439886-162	FOUNTAIN LEFT BY LOCKER ROOM 145	< 0.500	BS
L6439886-163	CLASSROOM 140 BATHROOM SINK	<15 ppb	TNR/BS
L6439886-164	CLASSROOM 111 BACK OFFICE SINK	>15 ppb	TNR/ SP
L6439886-165	GIRLS LOCKER ROOM 149 OFFICE SINK	< 0.500	BS
L6439886-166	CLASSROOM 114 SINK	3.040	TNR/BS
L6439886-167	CLASSROOM 111 SINK RIGHT	< 0.500	TNR/BS
L6439886-168	BOYS LOCKER ROOM OFFICE SINK	< 0.500	BS
L6439886-169	CLASSROOM 140 SINK RIGHT	< 0.500	TNR/BS
L6439886-170	CLASSROOM 116 SINK	2.070	TNR/BS

WAYNE HILLS HIGH SCHOOL

272 BERDAN AVE

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/8/16 & 5/31/17

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-171	CLASSROOM 127 SINK	<15 ppb	TNR/BS
L6439886-172	CLASSROOM 140 SINK LEFT	1.150	TNR/BS
L6439886-173	FOUNTAIN RIGHT BY MAIN OFFICE	< 0.500	BS
L6439886-174	CLASSROOM 109 SINK	>15 ppb	TNR/ SP
L6439886-175	DRESSING ROOM BY 112 SINK RIGHT	>15 ppb	TNR/ SP
L6439886-176	GYM FOUNTAIN BY BOYS LOCKER	1.580	BS
L6439886-177	FOUNTAIN IN BOYS LOCKER 145	< 0.500	BS
L6439886-178	FOUNTAIN BY CLASSROOM 141	0.780	BS
L6439886-179	KITCHEN 120 SINK ON BACK ISLAND	0.970	BS
L6439886-180	CLASSROOM 111 SINK LEFT	< 0.500	TNR/BS
L6439886-181	CLASSROOM 124 SINK	3.800	TNR/BS
L6439886-182	RECEPTION 159 SINK	< 0.500	BS
L6439886-183	CLASSROOM 113 SINK 2	0.550	TNR/BS
L6439886-184	FOUNTAIN BY ROOM 116	0.550	BS
L6439886-185	CLASSROOM 122 SINK	>15 ppb	TNR/ SP
L6439886-186	FOUNTAIN BY NORTH GYM 146	< 0.500	BS
L6439886-187	CLASSROOM 132 SINK	< 0.500	TNR/BS
L6439886-188	KITCHEN 120 COFFEE MAKER	0.810	BS
L6439886-189	CLASSROOM 113 SINK 3	1.260	TNR/BS
L6439886-190	SINK IN TEAM ROOM 147	3.920	BS
L6439886-191	KITCHEN 120 SINK ON ISLAND LEFT	3.020	BS
L6439886-192	FOUNTAIN LEFT BY MAIN OFFICE	< 0.500	BS
L6439886-193	MAIN OFFICE SINK	< 0.500	BS
L6439886-194	KITCHEN 120 SINK RIGHT	< 0.500	BS
L6439886-195	FOUNTAIN ACROSS FROM GUIDANCE	< 0.500	BS
L6439886-196	TRAINING ROOM 128 SLOP SINK	0.800	TNR/BS
L6439886-197	GIRLS LOCKER ROOM OFFICE SINK	>15 ppb	TNR/ SP
L6439886-198	AUTO SHOP SINK	<15 ppb	TNR/BS
L6439886-199	LAB 272 FRONT SINK 2	<15 ppb	TNR/BS
L6439886-200	LAB 272 SINK 2	<15 ppb	TNR/BS
L6439886-201	LAB 272 FRONT SINK 4	<15 ppb	TNR/BS
L6439886-202	LAB 272 FRONT SINK 6	<15 ppb	TNR/BS
L6439886-203	LAB 272 SINK 1	<15 ppb	TNR/BS
L6439886-204	LAB 272 FRONT SINK 3	<15 ppb	TNR/BS

WAYNE HILLS HIGH SCHOOL**272 BERDAN AVE****KEY: TNR: TESTING NOT REQUIRED****DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION****ND: None Detected BS: Below DEP / EPA Standard****SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY****Test Dates: 11/8/16 & 5/31/17**

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439886-205	LAB 272 FRONT SINK	>15 ppb	TNR/ SP
L6439886-206	LAB 272 FRONT SINK ON # 1	<15 ppb	TNR/BS
L6439886-207	LAB 272 FRONT SINK # 5	<15 ppb	TNR/BS
L6439886-208	LAB 272 PREP ROOM SINK	>15 ppb	TNR/SP
L6823852-1	CONCESSION FAUCET #3	ND	ND/BS
L6823852-2	CONCESSION FAUCET #2 (BLEACHERS)	1.100	BS
L6823852-3	CONCESSION FAUCET #1 (BLEACHERS)	2.350	BS